

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20131122-E120058  
**Report Reference** E120058-20131121  
**Issue Date** 2013-NOVEMBER-22

**Issued to:** MEASUREMENT TECHNOLOGY LTD  
GREAT MARLINGS  
BUTTERFIELD  
LUTON  
LU2 8DL UNITED KINGDOM

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS


Associated Apparatus for use in Unclassified Locations or  
Class I, Division 2, Groups A, B, C, D; Models MTL4541,  
MTL4541B, MTL4541P, MTL4544, MTL4544B, MTL5541  
and MTL5544

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20131122-E120058  
**Report Reference** E120058-20131121  
**Issue Date** 2013-NOVEMBER-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Standard(s) for Safety

UL 61010-1, Safety requirements for electrical equipment for measurement, control, and laboratory use - part 1: general requirements

ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements

UL 60079-11 Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

