

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx CML 16.0025X		Issue No: 0	Certificate history:
Status:	Current		Page 1 of 4	Issue No. 0 (2016-08-01)
Date of Issue:	2016-08-01			
Applicant:	Controlled Systems Ltd. Ryder Close, Swadlincote, Derbyshire DE11 9EU United Kingdom			
Equipment:	BxLAN Ethernet Interface			
Optional accessory:				
Type of Protection:	[Ex ia]			
Marking:	[Ex ia Ma] I [Ex ia Ga] IIC or IIB* [Ex ia Da] IIIC Ta = -40°C to +70°C * Refer to certificate Annex for fur	ther information on gas	group marking op	tions
Approved for issue on behalf of the Certification Body:	ne IECEx	A Snowdon		
Position:		Certification Officer		
Signature: (for printed version)		A Showld	DN	
Date:		August 1, 20	16	

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:



Certificate No: IECEx CML 16.0025X Issue No: 0

Date of Issue: 2016-08-01 Page 2 of 4

Certification Management Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port
CH65 4LZ
United Kingdom





Certificate No: IECEx CML 16.0025X Issue No: 0

Date of Issue: 2016-08-01 Page 3 of 4

Manufacturer: Controlled Systems Ltd.

Ryder Close, Swadlincote, Derbyshire DE11 9EU United Kingdom

Additional Manufacturing

location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-11 : 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the

Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/CML/ExTR16.0033/00

Quality Assessment Report:

GB/SIR/QAR07.0023/09



Certificate No:	IECEx CML 16.0025X	Issue No: 0
-----------------	--------------------	-------------

Date of Issue: 2016-08-01 Page 4 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

BxLAN Ethernet Interface

See Annex for full description and Conditions of Manufacture

CONDITIONS OF CERTIFICATION: YES as shown below:

See Annex for Conditions of Certification

Annex:

Certificate Annex IECEx CML 16.0025X Issue 0.pdf

Annexe to: IECEx CML 16.0025X, Issue 0

Applicant: Controlled Systems Ltd.

Apparatus: BxLAN Ethernet Interface



Product Description

The BxLAN Ethernet Interfaces are associated apparatus and are intrinsically safe interface devices which allow Ethernet to be extended into hazardous areas. The interfaces are intended to be incorporated into other larger apparatus, or may be supplied as stand-alone, boxed equipment. The following models are available:

Part no.	Data rate	Configuration	Suitable groups
9474-ETG	Gigabit	Boxed version	I, IIA, IIB, IIIC
9474-ET	10/100Mbps	Boxed version	I, IIA, IIB, IIC, IIIC
BxLAN-GE	Gigabit	PCB without enclosure	I, IIA, IIB, IIIC
BxLAN-OEM	10/100Mbps	PCB without enclosure (optional covers)	I, IIA, IIB, IIC, IIIC

Intrinsic safety is achieved by limiting the energy which can be transferred from the safe area to the hazardous area.

The equipment has the following safety description:

Safe area side SK1/PL1:

Um = 250V

Hazardous area side SK2/PL2:

10/100Mbps versions		Gigabit versions			
Uo	=	6.0 V	Uo	=	6.0 V
lo	=	2.24 A	lo	=	4.48 A
Po	=	1.16 W	Po	=	2.32 W
Ci	=	0.504 uF	Ci	=	0.504 uF
Li	=	0	Li	=	0
Ui	=	6.51 V	Ui	=	6.51 V

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the load connected to the hazardous area terminals must not exceed the following values:

Version	Group	Capacitance Co (μF)	Inductance Lo (μH)	Or	L/R ratio (μH/ohm)
10/100Mbps	I	999	93.0		139
10/100Mbps	IIA	999	56.7		70.8
10/100Mbps	IIB/IIIC	999	28.3		42.2
10/100Mbps	IIC	39	7.1		10.6
Gigabit		999	23.3		69.5

Unit 1, Newport Business Park New Port Road Ellesmere Port CH65 4LZ

T +44 (0) 151 559 1160 **E** info@cmlex.com

www.cmlex.com







Version	Group	Capacitance Co (μF)	Inductance Lo (μH)	Or	L/R ratio (μH/ohm)
Gigabit	IIA	999	14.2		35.4
Gigabit	IIB/IIIC	999	7.1		21.1

The above figures are based on the output voltage $U_0 = 6.0 \text{ V}$ and output current $I_0 = 2.24 \text{ A}$ or 4.48 A, and if any higher voltage or current is connected, these should be adjusted accordingly.

The hazardous area port may be connected to any other equipment having appropriate Entity parameters.

It is also permissible to be connected to 9400 Ethernet modules covered by these existing certificates (with or without PoEx):

9400 Ethernet module reference	Certificate No.
9400 Series Ethernet Modules	IECEx SIR 07.0042X
9468 Ethernet Isolator	IECEx SIR 07.0043
9468 Ethernet Isolator (Zone 2)	IECEx SIR 08.0032X

Marking

The equipment shall be marked with the following:

[Ex ia Ma] I [Ex ia Ga] IIC or IIB*

[Ex ia Da] IIIC

Ta = -40° C to $+70^{\circ}$ C Ta = -40° C to $+70^{\circ}$ C

* Models 9474-ETG and BxLAN-GE are marked IIB. Models 9474-ET and BxLAN-OEM are marked IIC.

Conditions of manufacture

None

Conditions of Certification/Special Conditions for Safe Use

The following conditions relate to safe installation and/or use of the equipment.

- i. When the equipment is supplied for incorporation into larger apparatus, it must be installed within an enclosure providing a minimum ingress protection of IP20.
- ii. When the equipment is supplied for incorporation into larger apparatus, separations between the PCB and all other voltage sources within the enclosure must be in accordance with Table 5 of IEC 60079-11.



- iii. The quoted entity parameters of Co and Lo are applicable for the distributed capacitance and inductance in cable. Where there is circuit capacitance or inductance in the connected equipment (represented by Ci and Li respectively), then these values shall not exceed 50 % of the quoted Co and Lo.
- iv. The safe area connection SK1 must only be connected to Ethernet sources which are not Power over Ethernet (PoE) capable.
- v. Identical connectors are used for the safe area and hazardous area connections. Equipment labelling for correct connections shall be observed.