

# ATEX Category 3 Certificate

Certificate of Conformity for Group II Category 3 G equipment in accordance with Directive 2014/34/EU.

Certificate relating to the following products:-

**MA15E/D/1/SI 120Vac/dc Power Surge Protection Device**

**MA15E/D/2/SI 240Vac/dc Power Surge Protection Device**

This equipment fulfils all the requirements for Group II, Category 3 G equipment in accordance with Directive 2014/34/EU when installed according to the Special Conditions of Safe Use listed below. The design complies with EN IEC 60079-0:2018, EN IEC 60079-7:2015+A1:2018 and EN 60079-15:2010. The analysis is fully documented in Technical File TF\_MA15E.

The connections of this equipment are non-sparking and increased safety in normal operation. The equipment in normal operation is incapable of producing arcs, sparks or hot surfaces which may cause ignition and is designed to be installed and used in accordance with EN 60079-14:2014. Note Special Conditions of Safe Use below.

The required marking of the apparatus is as specified in the Technical File referenced above and includes the distinctive community mark:



In addition, the marking will include the CENELEC codes:

**Ex ec IIC T4 Gc**

**Ex nA IIC T4 Gc**

The ec and nA markings signify that the equipment is incapable in normal operation of producing sparks or hot surfaces that may cause ignition.

The ambient temperature limitation for the equipment is -40°C to +70°C.

Manufacture is controlled by an ISO9001:2015 approved system.

The apparatus meets the ATEX Directive requirements for electromagnetic radiation by complying with the EMC Directive 2014/30/EU.

The standards published in the Official Journal of the European Commission with reference to the Low Voltage Directive 2014/35/EU have been used to fulfil the requirements of 1.2.7 of Annex II of directive 2014/34/EU to avoid electrical risks.

If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to Special Conditions of Safe Use specified elsewhere in this certificate.

#### **Input Parameters**

Model	MA15E/D/1/SI	MA15E/D/2/SI
Rated Voltage	120Vac/dc	240Vac/dc
Rated Current	15A	10A

#### **Special Conditions of Safe Use**

- 1) The equipment must be installed in an enclosure that provides a minimum degree of protection of IP54 in accordance with EN 60079-0.
- 2) All connections to the equipment must not be inserted or removed unless either the area in which the equipment is installed is known to be non-hazardous, or the circuit to which it is connected has been de-energised.
- 3) The equipment is fitted with transient protection devices and is incapable of withstanding the 500V dielectric strength test of clause 6.1 of EN 60079-7:2015+A1:2018 and clause 6.5.1 of EN 60079-15:2010. This must be taken into account when installing the equipment.