

# CERTIFICATE OF COMPLIANCE

**Certificate Number:** SGSNA/22/SUW/00076X

**Contract Number:** 801113  
**Certificate Project Number:** SUW-CERT220800145

**Certified Product:** Fieldbus Barrier System  
**Trademarks:** EATON  
**Model(s):** 937X-FB2-\*\*-\*\*, 93ZX-FB2-XX-XX-XXX (Fieldbus Barrier System)  
**Technical Data:** 487mA max; 16-32Vdc

**Certificate Holder:** Eaton Electric Limited  
Great Marlings, Butterfield, LU2 8DL, Luton, United Kingdom

*This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at [www.sgs.com](http://www.sgs.com) or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:*

UL 61010-1, 3rd Ed., Rev. July 19, 2019  
CAN/CSA C22.2 No. 61010-1-12 to November 21, 2018  
Conditions of Acceptability: Supplied power by certified SELV/LPS power source.

Authorized by:

Effective date: 14 September 2022



Paul Krauss  
Certifier



#### Certification Body

Connectivity & Products, a division of SGS North America Inc.  
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA  
t +1 770 570 1800 f +1 770 277 1240 [www.sgs.com](http://www.sgs.com)

