

CERTIFICATE OF CONFORMITY

FM Approvals

1. HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS

2. Certificate No:

FM25US0306X

3. Equipment:

(Type Reference and Name)

**AS-i Megablock Part number A10a-b. Actuator
Sensor Interface.**

4. Name of Listing Company:

Relcom Inc

5. Address of Listing Company:

**2221 Yew St, Forest Grove, Oregon 97116, United
States of America**

6. The examination and test results are recorded in confidential report number:

3019356 dated 19th March 2004

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM 3600:2022, FM 3611:2021, FM 3810:2021

8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

10. Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C and D; and Class I, Zone 2 IIC hazardous (classified) locations; Temperature Class is T4 Ta = -45°C ≤ Tamb ≤ 70°C

11. The marking of the equipment shall include:

Class 1 Div 2 ABCD T4

Class I Zone 2 IIC T4

-45°C ≤ Tamb ≤ 70°C

Install per Document No. 500-521

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

29 October 2025

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Jul 24)



Page 1 of 2

SCHEDULE

US Certificate of Conformity No: FM25US0306X



12. Description of Equipment:

AS-i Megablock Part number A10a-b. Actuator Sensor Interface.

a = Actuator Sensor Interface Series: 0, 1, 2, 3

b = Connection Interface: None, PC, PD

13. Specific Conditions of Use:

1. The product must be installed in a final equipment enclosure in compliance with, mounting, spacing and segregation requirements of the ultimate application, including the use of a tool secured cover.
2. When installed in Hazardous locations a warning label must be prominently affixed near the unit(s) which warns the equipment must not be disconnected unless the area is known to be non-hazardous.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
19 March 2004	Original Issue.
29 October 2025	<u>Supplement 1:</u> Report Reference: RR248106 dated 29 October 2025. Description of the Change(s): Gap analysis performed and update to new certificate format.

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Jul 24)



Page 2 of 2