



FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

FCS-MBT (Megablock Terminator) Fieldbus

NI/1/2/ABCD/ T4 Ta = 70°C -500-948

I / 2 / IIC / T4 Ta = 70°C -500-948

Special Condition of Use

1. The equipment shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

FCS-MB2ab, FCS-MB4ab, FCS-MB8ab, FCS-MB10ab, F200b-F212b, F118b, F100 (Megablock Terminator) Fieldbus

NI/1/2/ABCD/ T4 Ta = 70°C -500-275

I / 2 / IIC / T4 Ta = 70°C - 500-275

a = blank or -SG and/ or -T

Remove the "L" option.

b = blank, -PC, -PD

Special Condition of Use

1. The equipment shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C and D, and Class I, Zone 2, Group IIC indoor hazardous locations.

Approved for:

Relcom Incorporated
2221 Yew Street
Forest Grove, OR 97116



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3611	1999
Class 3810	1989

Original Project ID: 3013269

FM Approval Granted: August 12, 2002

Subsequent Revision Reports / Date FM Approval Amended

040422

May 7, 2004

FM Global Technologies LLC

Robert L. Martell, Jr.
Assistant Vice President

Date