

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion**  
**Directive 2014/34/EU**

3 EU - Type Examination Certificate **Baseefa14ATEX0387 – Issue 1**  
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **MTL4514N Switch / Proximity Detector Interface with Line Fault Detection Alarm**

5 Manufacturer: **Eaton Electric Limited**

6 Address: **Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL**

7 This re-issued certificate extends EC Type Examination Certificate No. Baseefa14ATEX0387 to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. See Certificate History

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 60079-0: 2012 + A11: 2013 EN 60079-11: 2012**

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

⊕ II (1) GD [Ex ia Ga] IIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)  
[Ex ia Da] IIIC (-20°C ≤ T<sub>a</sub> ≤ +60°C)

⊕ I (M1) [Ex ia Ma] I (-20°C ≤ T<sub>a</sub> ≤ +60°C)

SGS Baseefa Customer Reference No. **0703**

Project File No. **16/0371**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

**SGS Baseefa Limited**


Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601

e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/baseefa](http://www.sgs.co.uk/baseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN



R S SINCLAIR

TECHNICAL MANAGER

On behalf of SGS Baseefa Limited

13

## Schedule

14

Certificate Number Baseefa14ATEX0387 – Issue 1

### 15 Description of Product

The MTL4514N Switch / Proximity Detector Interface with Line Fault Detection alarm is designed to restrict the transfer of energy from unspecified non-hazardous area equipment to an intrinsically safe circuit by limitation of voltage and current. Relays and a transformer provide galvanic isolation between the hazardous and non-hazardous area circuitry.

The interface monitors either a detector or switch located in the hazardous area and control a non-hazardous area loads via relay. The interface is also fitted with independent phase reversal controls and Line Fault Detection (LFD) circuitry allowing an alarm condition to be signalled for either state, set by switches on the side of the interface. The interface has identification circuitry fitted on the non-hazardous area side of the circuit which allows it to be identified when fitted on specific backplanes.

The equipment comprises an isolating transformer, relays, zener diodes and current limiting resistors to provide voltage and current limitation. These, together with other electronic components are mounted on a single printed circuit board and housed in a plastic enclosure. Polarised plug and socket connections are provided for connection to the hazardous and non-hazardous area. LED indication is provided to indicate Power-on, state of the output and LFD status.

### Input / Output Parameters

#### Non-Hazardous Area Terminals 7 to 14

$$U_m = 253V$$

The circuit connected to non-hazardous area terminals pins 13 & 14 are designed to operate from a d.c. supply voltage of up to 35V d.c.

Non-hazardous area terminals pins 7 to 12 are connected to relay contacts which can switch up to 253V r.m.s, 2A r.m.s and 100VA.

#### Hazardous Area Terminals 1 w.r.t. 2 / 3

$$\begin{aligned} U_o &= 10.5V & C_i &= 0 \\ I_o &= 14mA & L_i &= 0 \\ P_o &= 37mW \end{aligned}$$

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area terminals must not exceed the following values:

GROUP	CAPACITANCE ( $\mu$ F)	INDUCTANCE (mH)	OR	L/R RATIO ( $\mu$ H/ohm)
IIC	2.41	175		983
IIB*	16.8	680		1,333
IIA	75.0	1,000		1,333
I	95.0	1,000		1,333

\* Group IIB parameters also applicable for associated apparatus [Ex ia Da] IIIC

Notes:

- The above load parameters apply when one of the two conditions below is given:
  - the total  $L_i$  of the external circuit (excluding the cable) is < 1% of the  $L_o$  value or
  - the total  $C_i$  of the external circuit (excluding the cable) is < 1% of the  $C_o$  value.



- 2) The above parameters are reduced to 50% when both of the two conditions below are given:
- the total  $L_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $L_o$  value and
  - the total  $C_i$  of the external circuit (excluding the cable) is  $\geq 1\%$  of the  $C_o$  value.

The reduced capacitance of the external circuit (including cable) shall not be greater than  $1\mu\text{F}$  for Groups IIB, IIA & I and  $600\text{nF}$  for Group IIC.

## 16 Report Number

GB/BAS/ExTR16.0237/00

## 17 Specific Conditions of Use

None

## 18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

## 19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
CI4514N-6	1 of 1	2	7.16	MTL4514N Certification Label Details – Baseefa – Ex i

The above drawing is associated and held with IECEx BAS 14.0174 Iss. 1

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
CI4500-100	1 of 1	2	1.13	MTL4500 Case
CI4514N-1	1 of 1	1	11.14	MTL4514N Circuit Diagram
CI4514N-2	1 & 2	1	11.14	MTL4514N Parts List
CI4514N-3	1 of 1	1	11.14	MTL4514N Track Layout
CI4514N-4	1 of 1	1	11.14	MTL4514N Component Layout
CI4514N-5	1 of 1	1	11.14	PCB Detail for TPL308

The above drawings are associated and held with IECEx Certificate No. IECEx BAS 14.0174

## 20 Certificate History

Certificate No.	Date	Comments
Baseefa14ATEX0387	18 February 2015	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0: 2012 and EN 60079-11: 2012 is documented in Certification Test Report No. GB/BAS/ExTR14.0351/00.

Certificate No.	Date	Comments
Baseefa14ATEX0387 Issue 1	26 September 2016	<p>This issue of the certificate confirms the current designs meet the requirements of EN 60079-0: 2012 + A11: 2013 in respect of differences from EN 60079-0: 2012.</p> <p>The certificate also permits the manufacturer's name to be changed on page 1 of the certificate and on the equipment marking.</p> <p>The associated assessment is documented in Certification Report No. GB/BAS/ExTR16.0237/00.</p>
For drawings applicable to each issue, see original of that issue.		